



# Adapting to Rising Salinity in the Floridian Aquifer


Jon Friedrichs, JLA Geosciences  
Jason Lee, Kimley-Horn and Associates, Inc.

## **Outline**

- Introduction to Jupiter Water Utilities
- FAS Wellfield Monitoring and Rehabilitation
- Wellfield Expansion
- FAS Wellhead Repairs and Re-design
- RO Plant Process Improvements

# Background

- Town of Jupiter Water Utilities
  - Jupiter, FL (SE coastal region)
  - Blended water supply
    - Reverse Osmosis
    - Nanofiltration
    - Anion Exchange
  - 30 MGD capacity
  - Population served: ~90,000



# SYSTEM DESCRIPTION

- Water Supply
  - 2 groundwater sources
  - Floridan aquifer
    - Deep, brackish wells
    - High in TDS and dissolved gases
  - Surficial aquifer
    - Shallow, fresh groundwater
    - High in hardness, TOC, color and iron



Floridan aquifer water supply well



Surficial aquifer water supply well

# Overview of Treatment

Facility Designed to Produce 30 MGD



**13.7 MGD Reverse Osmosis Process**  
Constructed in 1990  
Expanded in 1996 & 2005




**1.8 MGD Anion Exchange Process**  
Constructed in 2000




**14.5 MGD Nanofiltration Process**  
Constructed in 2010

# The UFA in South Florida

- Confined Carbonate Aquifer
- Top of Aquifer Between ~800 ft and 1100 ft.
- ~ 500-700 feet thick brackish water zone
- Artesian with Static WL's +20-30 Feet ALS.
- Brackish Water Quality
  - Chloride Concentration ~500-8000mg/L




# Degrading FAS Water Quality



# UFA WQ Degradation in S FL Wells

- WQ degradation over time due to:
  - Vertical intrusion of poorer WQ from above, below and laterally.
  - Over pumping
  - Wellfield Interference.
  - High Drawdown
  - Declining Well Performance
- What to do about WQ Degradation:
  - Decrease pumping rates
  - Add more wells.
  - Rehabilitation, acidization deepen borehole, deepen casing (liner), back plugging.









# UFA Wellfield Testing Program

- Annual water quality and well performance testing started in 2014.
- Identified wells with performance and water quality changes.
- Recommendations to reduce the rate of WQ degradation and improve well performance included:
  - Well Rehabilitation/Acidization
  - Reducing pumping rates (from ~2.0 to 1.0-1.5 MGD/Well)
  - Wellfield Expansion (increase number of wells)


# UFA Well performance



- Well Perf. Degradation = Reduced Raw Water Capacity
- Specific Capacity = GPM/Ft. of Drawdown (DD)
- $< \text{Specific Capacity} = > \text{DD}$
- $> \text{DD} = \text{Lower Pumping Rate}$
- Individual well pumping rates reduced from 1.5-2.0 MGD to 1.0-1.5 MGD
- Total Raw Water Cap. reduced from ~20.5 to 16.0 MGD.
- Acidization of UFA wells increases specific capacity and reduces DD.

# UFA Well Rehab. (Acidization)

- Acidization Program (2016-2021).
- Acidized 9 Wells using between 10,000-20,000 gallons 32% HCl per Well
- Increased Well Specific Capacities by 27% -189%
- Post Acidization Pumping Water Levels at or above land surface at pumping rates between 1.0 and 2.0 MGD.






# UFA Well Rehab. (Back Plugging)

- RO-2 & RO-3: longest serving and historically some of the best producing wells.
- Deepened in 1997.
- Between 1997 and 2020 Chlorides increased by ~260% (2020 TDS ~5000-5500 mg/L)
- Current membranes could not handle RO-2 & Ro-3 raw water resulting in ~3 MGD raw water loss from existing wells!




# UFA Well Rehab. (Back Plugging)


- Pre Rehab pump testing investigation: TDS higher at lower pumping rates.
- Geophysical logging investigation: TDS higher & majority of flow at bottom of borehole.
- Results: RO-2 TDS and specific capacity reduced by ~54% by ~29%.
- Results: RO-3 TDS and specific capacity reduced by ~38% by ~53%.
- Rehab effort reclaimed 2 MGD of treatable raw water capacity from existing wells!




# UFA Well Rehab. (Water Quality)



# UFA Well Rehab. (Water Quality)



# FAS Wellfield Expansion



## Legend

- Modified Locations of Proposed FAS Wells
- Location of Existing FAS Wells
- Model-Predicted Drawdown in FAS with Currently Permitted 16 FAS Wells Pumping 18.5 MG (1-ft CI)
- Model-Predicted Drawdown in FAS with 18 FAS Wells Pumping 18.5 MGD (1-ft CI)

0 2,600 5,200  
Feet



# Original FAS Wellhead Design (FRP Well Casing )

- First Generation Well Design
- Constructed in late 1980s to early 1990s
- FRP Casings and carbon steel surface casings



# Original FAS Wellhead Design (PVC Well Casing )

- Second Generation Well Designs
- Certa-Lok PVC Casings and carbon steel surface casings



# Wellhead Deterioration (FRP Well Casing )

- Deterioration of FRP
- Evidence of casing leak



# Wellhead Deterioration (PVC Well Casing )

- PVC Casing Deterioration




# Wellhead Repair/Redesign



FRP Casing  
Repair



FRP Casing  
Repair



PVC Casing  
Repair

# Wellhead Repair/Redesign



New well casing



New surface casing

# Wellhead Repair/Redesign



Well pad reinforcement with gusset plate to surface casing



Wellhead support table and flushing tee

# Wellhead Repair/Redesign



Vertical Turbine Pump  
Application




Horizontal End Suction  
Pump Application



# Reverse Osmosis Treatment

- Master Plan Development
- Three Phased Approach
  - Phase 1: 4,700 to 7,300ppm TDS
  - Phase 2: 7,300 to 8,500ppm TDS
  - Phase 3: 8,500 to 11,500ppm TDS

# Reverse Osmosis Treatment



Bank I includes Trains A, B, C, and D

# Reverse Osmosis Treatment



Bank II includes Trains E, F, G, and H

# Reverse Osmosis Treatment



Train I

# Phase 1

- Bank I Membrane Replacement
- Bank 1 Array Change
  - Match Bank 2
- ERD Replacement
- Interstage Piping Replacement
  - Serve Through Phase 3



Master Plan Phase	Raw Water Quality TDS (PPM)	Min. Feed Pressure (psi)	Max. Feed Pressure (psi)	Min. Boost Pressure (psi)	Max. Boost Pressure (psi)
1	4,700 - 7,300	162.2	238.6	55.5	127

# Phase 2



## Membrane Replacement

Master Plan Phase	Raw Water Quality TDS (PPM)	Min. Feed Pressure (psi)	Max. Feed Pressure (psi)	Min. Boost Pressure (psi)	Max. Boost Pressure (psi)
2	7,300 - 8,500	234.6	282	117.7	140

# Phase 3

- Interstage Booster Pump
- Elevate Raw Water Pressure
- Pressure Vessel Replacements
- Stage 2 Permeate Second Pass



Master Plan Phase	Raw Water Quality TDS (PPM)	Min. Feed Pressure (psi)	Max. Feed Pressure (psi)	Min. Boost Pressure (psi)	Max. Boost Pressure (psi)
3	8,500 - 11,500	231.1	362.1	103	144.5